



Decommissioning **San Onofre**

Nuclear Generating Station

Dry Cask Storage Monitoring

Randall Granaas, PE
SCE Nuclear Fuel / ISFSI
Engineer

Eric M Goldin, PhD
Certified Radiation Protection
Professional



Decommissioning
San Onofre
Nuclear Generating Station

Why Survey Outlet Vents?

- During the August 20 CEP meeting, Donna Gilmore asked about a survey of the outlet air vents of the NUHOMS dry spent fuel storage modules.
- From her website, the contention is: “The NRC and Southern California Edison continue to refuse to provide the radiation levels from the outlet (rooftop) air vents of the aging Areva NUHOMS thin-wall canister systems at San Onofre. The San Onofre canisters are only 5/8” thick and some are already 17 years old. What are they hiding?”
- Measuring the outlet air vents not necessary because surveying areas accessible from ground level will identify radioactive contamination in the unlikely event of canister leakage, with lower industrial safety risk to workers.
- We decided to survey the outlet vents to put to rest this contention about the NUHOMS dry fuel storage system.

2



Decommissioning
San Onofre
Nuclear Generating Station


Orano (AREVA) NUHOMS Storage Module and Canister

Outlet Vent

Concrete

Canister


Inlet Vent





Decommissioning
San Onofre
Nuclear Generating Station


Special Survey of NUHOMS Storage Module Outlet Vents





Decommissioning
San Onofre
Nuclear Generating Station

Independent Radiation Surveys Performed by Philotechnics Ltd.





Decommissioning
San Onofre
Nuclear Generating Station

All Modules Surveyed for Radiation and Contamination


- Radiation readings were taken at each outlet vent on all 51 NUHOMS modules
 - Survey meter measures down to background levels
 - Assayed for any airborne radioactivity
- Contamination assessment done at each outlet vent using large area smear surveys

AHSM #	Lowest Dose Rate in $\mu\text{R/hr}$ (closed)	Highest Dose Rate in $\mu\text{R/hr}$ (closed)
1	40	50
2	20	40
3	25	55
4	20	50
5	40	45
6	40	45
7	40	50
8	40	50
9	45	40
10	45	50
11	40	55
12	40	60
13	45	45
14	30	40
15	20	
16	30	

Full data in appendix and online [click here](#)

Results Show Outlet Vent Readings Lower than Inlets

- Single Row Modules ~0.040 to .060 mrem/hr (millirem per hour) at outlet vents
- Double Row Modules ~0.050 to 0.300 mrem/hr at outlet vents (double row modules combine radiation from shared outlet vent and have slightly less shielding due to adjacent outlet air vents)
- Inlet vent readings, while quite low, are higher than outlet vent readings as expected based on storage module design (greater shielding at outlet vent)
- No contamination found on any of the outlet vents
- No indication of airborne radioactivity at any module





Decommissioning
San Onofre
Nuclear Generating Station

SCE Quarterly Survey of NUHOMS Inlet Vents

- Radiation levels at inlet vents from ~0.2 to 0.85 mrem/hr
- No radioactive contamination detectable on modules
- Low levels do not require Radiation Area posting
- Note this quarterly survey is in units of microrem/hr (= 0.001 mrem/hr)

Survey #: SDS-RP1-SRV- 5581 Description: Q002, F ISFSI QUARTERLY Date: 09/02/2020 Time: 0815
Unit: N Area: VD ELV: 20' RM: N/A Surveyor Name(s): (Print) [Redacted]
RWP: 20-0-100 Peer Check: [Signature] Air Sample Taken: ☐ Yes ☒ No Field Check <0.3DAC ☐ Yes ☒ No ☐ N/A
☐ Shutdown (SD) Rad Posting: SEE MAP BELOW
Instrument Model Serial #
ALLEN C881C
ASPI/WRD 1839
2-1 271271
Smears (dpm/100cm²) Masslins dpm/wipe
B-y α # B-y α # B-y
1 11 A
2 12 B
3 13 C
4 14 COMMENTS D
5 15 SECTION E
6 16 DETAILS F
7 17 G
8 18 H
9 19 I
10 20 J
Hot Particles Detected: ☐ YES ☐ No ☒ N/A
Survey Reason:
☒ Routine
☐ Investigational
☐ Release
☐ RWP (Work Planning)
☐ Other (specify)
Comments:
☐ Component
☐ Shielding Recommended
☐ Released
☐ None
☒ Other (Specify) SEE BELOW
Additional Comments
ALL CONTACT DOSE RATES ARE
TAKEN ON MODULE VENTS
NEUTRON DOSE RATES < 0.2 MREM/HR
SMEARS TAKEN ON MODULE VENTS ARE < 1K DPM/100 CM²
RPS Approval (Print) [Redacted] Signature: [Redacted]

All dose rates in mrem/hr unless otherwise noted
* ALL DOSE RATES BY ARE IN MREM/HR.
ISFSI Pad North End (Modules 16 - 51)

Module	Dose Rate (mrem/hr)	Module	Dose Rate (mrem/hr)
#33	500/250	#32	650/300
#35	500/250	#34	550/350
#37	500/300	#36	550/300
#39	600/300	#38	600/350
#41	500/300	#40	550/300
#43	250/120	#42	550/300
#45	250/120	#44	200/100
#47	250/150	#46	200/100
#49	350/200	#48	400/250
#51	220/150	#50	250/150
#53 - EMPTY		#52	850/500
#55 - EMPTY		#54	700/450
		#31	400/200
		#30	600/100
		#29	500/350
		#28	400/200
		#27	500/300
		#26	300/150
		#25	300/100
		#24	400/250
		#23	500/300
		#22	500/300
		#21	850/500
		#20	700/450
		#19	700/450
		#18	300/150
		#17	300/150

Warning - Do Not
Tamper With. Remove
or After Emergencies
Radiation Levels May
Increase



Decommissioning
San Onofre
Nuclear Generating Station

SCE Monthly Surveys Show the Spent Fuel is Safely Stored

- ~0.010 mrem/hr at publicly accessible boundaries
- Background in the SONGS vicinity is ~0.010 mrem/hr
- Federal limit is 25 millirem per year (mrem/yr) above background; annual reports show <1 mrem/yr

Survey #: SDS-RP1-SRV-5579 Description: MOI Monthly Routine Date: 9-2-2020 Time: 1400

Unit: 1 Area: PD ELV: 20 RM: N/A Surveyor Name: [Signature] Sign: [Signature]

RWP: N/A Peer Check: [Signature] Air Sample Taken: ☐ Yes ☒ No Field Check <0.3DAC ☐ Yes ☒ No N/A

☐ Shutdown (SD) Rad Posting: N/A

Instrument Model: Micro-R Serial #: B0380

Smears (dpm/100cm²)

#	β-γ	α	#	β-γ	α	#	β-γ
1			11			A	
2			12			B	
3			13			C	
4	<u>N</u>		14	<u>N</u>		D	
5			15			E	<u>N</u>
6	<u>A</u>		16	<u>A</u>		F	
7			17			G	<u>A</u>
8			18			H	
9			19			I	
10			20			J	

Masslinns dpm/wipe

Hot Particles Detected: ☐ YES ☐ No ☒ N/A

Survey Reason:

☐ Job Coverage
☒ Routine
☐ Investigational
☐ Release
☐ RWP (Work Planning)
☐ Other (specify)

Comments:

☐ Component
☐ Shielding Recommended
☐ Released
☒ None
☐ Other (Specify)

Additional Comments: N/A

RPS Approval (Print): [Signature] (Signature): [Signature] Date: 9-3-2020 Page 2 of 4

All dose rates in mrem/hr unless otherwise noted

NIA RP Monitoring TLDs

Dose Rates along the NIA Boundary verified to be <200 μRem/hr (<0.2mR/hr) Initial here 26

Any dose rates > 50 μRem must be reported to HP Supervision for evaluation by HP Technical Support

ALL DOSE RATES IN μREM PER HOUR

OSL LOCATION	DOSE RATE	LIMIT
NIA-01	<u>7</u>	200
NIA-02	<u>10</u>	200
NIA-03	<u>8</u>	200
NIA-04	<u>9</u>	200
NIA-05	<u>6</u>	200
NIA-11	<u>9</u>	200
NIA-14	<u>9</u>	200
NIA-16	<u>9</u>	200
ISFSI Bldg #1	<u>12</u>	200
ISFSI Bldg #2	<u>10</u>	200



Decommissioning
San Onofre
Nuclear Generating Station

ISFSI Radiation Monitoring Monthly Reports Available Online

- Data streamed to CA Department of Public Health, Radiologic Health Branch (CDPH)
 - Publishes monthly reports
 - Provides high, low, and average radiation levels at each monitor
- CDPH publicly available online
 - <https://www.cdph.ca.gov/Programs/CEH/DRSEM/Pages/RHB-Environment/SONGS-ISFSI-reports.aspx>
- SONGS website provides contextual information and a link to CDPH reports
 - <https://www.songscommunity.com/stewardship/environmental-monitoring-around-san-onofre/dry-fuel-storage-radiation-monitoring>

